



# M & H VALVE COMPANY

605 West 23rd. St., Anniston, Alabama 36201 \* (256) 237-3521 \* Fax: (256) 741-6253

---

## CERTIFICATE OF COMPLIANCE & TESTING

### 2" -36" AWWA C508 Check Valves Model 59-02 Plain Swing, Model 159-02 Lever & Weight, and Model 259-02 Lever & Spring

**General Information:** Check valves shall be all iron body, bronze mounted, full opening swing type. Valve clapper shall swing completely clear of the waterway when valve is full open, permitting a "full flow" thru the valve equal to the nominal pipe diameter. They meet or exceed all requirements of AWWA C508 latest revision.

**Rating:** Check Valves shall be rated at 175 psi water working pressure, 350 psi hydrostatic test for structural soundness (2" through 12") and 150 psi water working pressure, 300 psi hydrostatic test sizes (14" through 36"). Seat tightness at rated working pressure meets or exceeds all requirements of AWWA C-508 standard, latest revision.

**2" – 12" Check Valves** – Are manufactured by Kennedy Valve Company. (M&H, Kennedy, and Clow are cast on the cover plate)

**14" – 36" Check Valves** – Are manufactured by M&H Valve Company. (M&H is cast on each side of check valve body. M&H, Kennedy, Clow, and ARD are cast on cover plate)