

CERTIFICATE OF COMPLIANCE & TESTING

AWWA C502 Dry-Barrel Fire Hydrants

This is to certify that M&H Model 129 and Model 929 Fire Hydrants meet or exceed all requirements of AWWA C502, latest revision. M&H Model 129 and Model 929 Fire Hydrants are certified to NSF 61, Annex G. In addition, M&H Model 129 and Model 929 Fire Hydrants have been tested for compliance and are listed by Underwriters Laboratories (UL246 – Hydrants for Fire Protection Service) and approved by Factory Mutual (FM1510 – Fire Hydrants [Dry Barrel Type] for Private Fire Service). These hydrants are manufactured in the USA at M&H Valve Company, Anniston, Alabama.