

## CERTIFICATE OF COMPLIANCE & TESTING

### 2" -12" C509 RESILIENT WEDGE GATE VALVE

M&H Valve Company manufactures 2"-12" resilient wedge gate valve, model 4000 series/ASTM gray iron in a non-rising configuration with an optional indicator post plate on sizes 4"-12". Valves equipped with an indicator post plate in conjunction with a 2945/2945A indicator post are compliant with the requirements of NFPA24. All valves will be rated for 250 psig working pressure and are hydrostatically tested for shell leakage at pressures up to 500 psig. All valves are tested and manufactured in full compliance with ANSI/AWWA C509 Standard for Resilient-Seated Gate Valves for Water Supply Service, latest revision. In addition, the 4"-12" valves have been tested for compliance with UL262 and approved by Underwriter Laboratories, Inc. Factory Mutual has tested and approved the valves for compliance with the FM Standard for Fire Service Water Control Valves. The bond of the rubber wedge closure member has been tested for adhesion per the ASTM D429 Standard, using an actual assembly. The end flanges of all flanged valves conform to the dimension and drillings of the ANSI/ASME B16.1 Class 125# Standard. The sealing surface of the end flanges also conform to the MSS Standard Practice SP-6, Standard Finishes for Contact Faces of Pipe Flanges and Connecting-End Flanges of Valves and Fittings. Mechanical joint bell dimensions conform to ANSI/AWWA C111/A21.11. The end flange of tapping valves conforms to MSS Standard Practice SP-60, Connecting Flange Joint between Tapping Sleeves and Tapping Valves. All non-machined interior and exterior surfaces of the valve are coated with an inert, thermosetting epoxy resin to provide a corrosion-resistant coating which complies with the performance requirements of ANSI/AWWA C550 Standard. All 4"-12" size valves are NSF61, Annex G certified by NSF International. The valves are being supplied with EPDM wedges. The temperature rating for these valves is 33-125 degrees F as required in the AWWA C509 Standard. These valves are **manufactured in the USA** by M&H Valve Company in Anniston, Alabama.

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140401-EX4526  
**Report Reference** EX4526-20030625  
**Issue Date** 2014-APRIL-01

**Issued to:** M&H VALVE CO DIV OF MCWANE  
605 W 23RD ST  
ANNISTON AL 36201


**This is to certify that  
representative samples of** GATE VALVES  
See adendum page

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** UL 262, Standard for Safety for Gate Valves for Fire-  
Protection Service

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's  
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the  
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category  
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140401-EX4526  
**Report Reference** EX4526-20030625  
**Issue Date** 2014-APRIL-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Gate Valves-

Pattern	Model	Size, in.	End Configuration
NRS	4067	2-1/2, 3	Flanged, Threaded, PVC
NRS	4067	4, 6, 8, 10, 12	Flanged, MJ, Tyton, PVC, Flange by MJ, MJ by Tap, Flange by Tyton



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

