

**CERTIFICATE OF COMPLIANCE & TESTING**

**Style 229 Flush Hydrant**

This is to certify that M & H Style 229 Fire Hydrants meet or exceed all requirements of AWWA C502 latest revision. This is to certify the 229 hydrants are tested at 250 psi water working pressure and tested at 500 psi hydrostatic. This is to certify the 229 hydrants are manufactured in the United States of America. These hydrants are manufactured in the USA at M&H Valve Company, Anniston, Alabama.