



M & H VALVE COMPANY

605 West 23rd. St., Anniston, Alabama 36201 * (256) 237-3521 * Fax: (256) 741-6253

CERTIFICATE OF COMPLIANCE & TESTING

Style 229 Flush Hydrant

This is to certify that M & H Style 229 Fire Hydrants meet or exceed all requirements of AWWA C502 latest revision. This is to certify the 229 hydrants are tested at 250 psi water working pressure and tested at 500 psi hydrostatic. This is to certify the 229 hydrants are manufactured in the United States of America. These hydrants are manufactured in the USA at M&H Valve Company, Anniston, Alabama.